

ANNUAL
WATER REPORT

*Water testing
performed in 2010*

Presented By _____
Oldham County Water District

Quality First Quality

Once again we are proud to present our annual water quality report covering all testing performed between January 1 and December 31, 2010. As in years past, we are committed to delivering the best-quality drinking water possible. To that end, we remain vigilant in meeting the challenges of new regulations, source water protection, water conservation, and community outreach and education while continuing to serve the needs of all of our water users. Thank you for allowing us to continue providing you and your family with high-quality drinking water.

We encourage you to share your thoughts with us on the information contained in this report. Should you ever have any questions or concerns, we are always available to assist you.

Community Participation

You are invited to participate in our public forum and voice your concerns about your drinking water. We meet the second Tuesday of each month beginning at 6 p.m. at the Buckner Office, 3707 West Highway 146, LaGrange, Kentucky.

Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The U.S. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791 or www.epa.gov/drink/hotline/.

Substances That Could Be in Water

To ensure that tap water is safe to drink, the U.S. EPA prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, in some cases, radioactive material, and substances resulting from the presence of animals or from human activity. Substances that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife;


Inorganic Contaminants, such as salts and metals, which can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and may also come from gas stations, urban stormwater runoff, and septic systems;

Radioactive Contaminants, which can be naturally occurring or may be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.



Tap vs. Bottled

Thanks in part to aggressive marketing, the bottled water industry would have you believe that water purchased in bottles is a healthier alternative to tap water. However, according to a four-year study conducted by the Natural Resources Defense Council, bottled water is not necessarily cleaner or safer than most tap water. In fact, about 25 percent of bottled water is actually just bottled tap water (40 percent according to government estimates).

The Food and Drug Administration is responsible for regulating bottled water, but these rules allow for less rigorous testing and purity standards than those required by the U.S. EPA for community tap water. For instance, the high mineral content of some bottled waters makes them unsuitable for babies and young children. Further, the FDA completely exempts bottled water that's packaged and sold within the same state, which accounts for about 70 percent of all bottled water sold in the United States.

People spend 10,000 times more per gallon for bottled water than they typically do for tap water. If you get your recommended eight glasses a day from bottled water, you could spend up to \$1,400 annually. The same amount of tap water would cost about 49 cents. Even if you installed a filter device on your tap, your annual expenditure would be far less than what you'd pay for bottled water.

For a detailed discussion on the NRDC study results, check out their Web site at www.nrdc.org/water/drinking/bw/exesum.asp.

Where Does My Water Come From?

Oldham County Water District customers are fortunate because we enjoy an abundant water supply from a groundwater source. The Oldham County Water Treatment Plant draws water from the Ohio River alluvium, which holds several billion gallons of water. The Oldham County Water Treatment Plant was constructed in 1981 to draw from this underground water supply. This groundwater supply is constantly being replenished with water from the Ohio River along with natural trans- evaporation. The treatment facility provides roughly 1.5 billion gallons of clean drinking water every year.

Water Conservation

You can play a role in conserving water and saving yourself money in the process by becoming conscious of the amount of water your household is using and by looking for ways to use less whenever you can. It is not hard to conserve water. Here are a few tips:

- Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- Turn off the tap when brushing your teeth.
- Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- Check your toilets for leaks by putting a few drops of food coloring in the tank. Watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from an invisible toilet leak. Fix it and you save more than 30,000 gallons a year.
- Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances. Then check the meter after 15 minutes. If it moved, you have a leak.

Information on the Internet

The U.S. EPA Office of Water (www.epa.gov/watrhome) and the Centers for Disease Control and Prevention (www.cdc.gov) Web sites provide a substantial amount of information on many issues relating to water resources, water conservation and public health. Also, the Kentucky Division of Water, Drinking Water Branch, has a Web site (<http://water.ky.gov/Pages/default.aspx>) that provides complete and current information on water issues in Kentucky, including valuable information about our watershed.

Questions?

For more information about this report, or for any questions relating to your drinking water, please contact Russell D. Rose, Superintendent, at (502) 222-1690 or visit our Web site at www.oldhamcountywater.com.

Lead in Home Plumbing

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Oldham County Water District is responsible for providing high-quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.



Why do I get this report each year?

Community water system operators are required by Federal law to provide their customers an annual water quality report. The report helps people make informed choices about the water they drink. It lets people know what contaminants, if any, are in their drinking water and how these contaminants may affect their health. It also gives the system operators a chance to tell customers what it takes to deliver safe drinking water.

Why does my water sometimes look “milky”?

The “milky” look is caused by tiny air bubbles in the water. The water in the pipes coming into your home or business might be under a bit of pressure, and gasses (the air) are dissolved and trapped in the pressurized water as it flows into your glass. As the air bubbles rise in the glass, they break free at the surface, thus clearing up the water. Although the milky appearance might be disconcerting, the air bubbles won't affect the quality or taste of the water.

How can I keep my pet's water bowl germ free?

Veterinarians generally recommend that water bowls be washed daily with warm, soapy water — normally when you change the water. Scour the corners, nooks, and crannies of the water dish using a small scrub brush. In addition, once a week put water bowls into the dishwasher to sanitize them with hot water. In most situations, disinfectants like bleach are not needed; warm, soapy water is all you need to keep your pet's water clean and safe.

How much water is used during a typical shower?

The Federal Energy Policy Act set a nationwide regulation that limits shower heads to a maximum flow of 2.5 gallons per minute (GPM). Shower heads made before 1980 are rated at 5 GPM. Since the average shower is estimated to last 8.2 minutes, the old shower heads use 41 gallons of water while the newer, low-flow shower heads use only about 21 gallons.

Is it okay to use hot water from the tap for cooking and drinking?

No, ALWAYS use cold water. Hot water is more likely to contain rust, copper, and lead from household plumbing and water heaters. These substances can dissolve into hot water faster than they do into cold water, especially when the faucet has not been used for an extended period of time.

How many contaminants are regulated in drinking water?

The U.S. EPA regulates over 80 contaminants in drinking water. Some states may choose to regulate additional contaminants or to set stricter standards, but all states must have standards at least as stringent as the U.S. EPA's.

Naturally Occurring Bacteria

The simple fact is, bacteria and other microorganisms inhabit our world. They can be found all around us: in our food; on our skin; in our bodies; and, in the air, soil, and water. Some are harmful to us and some are not. Coliform bacteria are common in the environment and are generally not harmful themselves. The presence of this bacterial form in drinking water is a concern because it indicates that the water may be contaminated with other organisms that can cause disease. Throughout the year, we tested many water samples for coliform bacteria. In that time, none of the samples came back positive for the bacteria. Federal regulations now require that public water that tests positive for coliform bacteria must be further analyzed for fecal coliform bacteria. Fecal coliform are present only in human and animal waste. Because these bacteria can cause illness, it is unacceptable for fecal coliform to be present in water at any concentration. Our tests indicate no fecal coliform is present in our water.

About Our Violations

Treatment Technique Violation

Violation Type: 41 Failure Maintain Microbial Treat. (GWR)

Date and Length of Violation: Compliance period 8/1/2010 to 8/31/2010 and 9/1/2010 to 9/30/2010

Steps Taken to Correct Violation: Our water system violated a drinking water requirement. We received a notice of violation (NOV) for August 2010 and also for September 2010. Although these incidents were not an emergencies, you, as our customers, have a right to know what happened and what we did to correct this situation.

We are required to disinfect our drinking water source, the Ohio River Alluvium. From August 31, 2010 to September 1, 2010, we did not meet one or more of our treatment requirements to provide sufficient levels of disinfectant due to a mechanical failure in our chlorination process. As a result, we failed to submit adequate sampling results to meet chlorine summary requirements for the compliance periods of 8/1/2010 to 8/31/2010 and 9/1/2010 to 9/30/2010.

Measurements of disinfectant indicate that adequate disinfection did not occur for the period indicated. Adequate disinfection is required to ensure safe drinking water.

We corrected the mechanical failure, issued a system-wide Boil Water Advisory, flushed water lines, and sent samples to our lab for testing. The mechanical problem was resolved on September 1, 2010, and the water samples were declared clean on September 2, 2010.

Health Effects: Inadequately treated or inadequately protected water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

Public Notification Violation

There was no Secondary Public Notice Method completed for the violations issued for the compliance periods of 8/1/2010 to 8/31/2010 and 9/1/2010 to 9/30/2010. All Public Notices must be mailed or hand delivered as the primary distribution method. A secondary method like newspaper or posting is also required. We failed to do a secondary method of delivery, and this resulted in an additional violation for not doing the public notification correctly.

Please share this information with all of the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or by distributing copies by hand or mail.

Sampling Results

During the past year we have taken hundreds of water samples in order to determine the presence of any radioactive, biological, inorganic, volatile organic, or synthetic organic contaminants. The tables below show only those contaminants that were detected in the water. The state requires us to monitor for certain substances less often than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

REGULATED SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	MCLG [MRDLG]	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Alpha Emitters (pCi/L)	2009	15	0	0.43	0.43–0.43	No	Erosion of natural deposits
Chlorine (ppm)	2010	[4]	[4]	0.87	0.33–1.4	No	Water additive used to control microbes
Combined Radium (pCi/L)	2009	5	0	0.54	0.54–0.54	No	Erosion of natural deposits
Fluoride (ppm)	2010	4	4	0.93	0.8–1.05	No	Erosion of natural deposits; Water additive that promotes strong teeth; Discharge from fertilizer and aluminum factories
Haloacetic Acids [HAAs] (ppb)	2010	60	NA	4	ND–9	No	By-product of drinking water disinfection
Nitrate (ppm)	2010	10	10	1.34	0.51–1.34	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
TTHMs [Total Trihalomethanes] (ppb)	2010	80	NA	19	12–18	No	By-product of drinking water disinfection
Thallium (ppb)	2008	2	0.5	1	1–1	No	Leaching from ore-processing sites; Discharge from electronics, glass, and drug factories
Uranium (ppb)	2009	30	0	0.07	0.07–0.07	No	Erosion of natural deposits

Tap water samples were collected for lead and copper analyses from sample sites throughout the community

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AL	MCLG	AMOUNT DETECTED (90TH%TILE)	SITES ABOVE AL/TOTAL SITES	VIOLATION	TYPICAL SOURCE
Copper (ppm)	2010	1.3	1.3	0.396	0/31	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	2010	15	0	1.9	0/31	No	Corrosion of household plumbing systems; Erosion of natural deposits

Definitions

AL (Action Level): The concentration of a contaminant, which if exceeded, triggers treatment or other requirements which a water system shall follow.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not applicable

ND (Not detected): Indicates that the substance was not found by laboratory analysis.

pCi/L (picocuries per liter): A measure of radioactivity.

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter).

ppm (parts per million): One part substance per million parts water (or milligrams per liter).